

AUSID09-RD Custodian's Alarm Panel



The AUSID09-RD Custodian's Alarm Panel is the direct replacement for Conspec's obsolete P2259/60-RAU and meets NYCSCA specification requirements for Natural Gas Leak Detection Equipment found in Section 15596. When natural gas from the sensors exceeds the alarm points, the audible alarm and/or visual alarm is activated.

Designed with a new touch screen human-to-machine interface, users can observe gas values for individual sensors and activate an acknowledge button upon alarms.

Mechanical

Enclosure - NEMA 4X
Dimensions - 8"x6"x4"
Mounting - Four mounting holes w/ optional mounting feet

Electrical

Operating Voltage - 24 VDC (from AUSID09 Controller)
Output - 240 VAC 10A (RES) 30VDC 10A (RES)

System

Touch-screen HMI (Human-to-Machine Interface)
Visual Alarm - Allen Bradley Clear Strobe Light
Audible Alarm - UL Listed 85dB Piezo - Electric Alarm
Acknowledge Button - Touch-screen

Warranty

Two years limited warranty